

## GENERAL SERVICES ADMINISTRATION



*Public Buildings Service*  
*Washington 25, D. C.*

DEC 19 1957

In Reply Refer To: PCM  
Langley, Va., CIA Bldg.  
Project No. 44122

Harrison & Abramovitz  
630 Fifth Avenue  
New York 20, N. Y.

Gentlemen:

Reference is made to the Outline Specifications for Heating, Ventilating and Air Conditioning Work, dated August 2, 1957, which you submitted. It is requested that changes be made in certain items, as follows:

1. Page H-1, Item H-01, a. 1 (a) (3)—Steam pressure for hot water heaters should be 5 to 10 pounds (See also Item H-01, a. 6 (b)).
2. Page H-1, Item H-01, a. 3—Humidification is not desired for general office space. It is to be provided for E.D.P.M. and other areas where required by processes therein, and in nearby office spaces only where it is not economically feasible to provide separate apparatus.
3. Page H-6, Items H-07, a. and d.—Air conditioning should be provided for locker rooms and custodial spaces (shops).

Sincerely yours

(Signed) E. W. Goodwin  
E. W. Goodwin  
Director, Mechanical  
and Electrical Division

Document No. \_\_\_\_\_  
Review of this document by CIA has  
determined that  
 CIA has no objection to declass  
 It contains information of CIA  
interest that must remain  
classified at TS S G  
Authority: HR 70-2  
 It contains nothing of CIA interest  
Date 2/04/81 Reviewer 018996