

24 April 1964

9/54/151

MEMORANDUM FOR: Chief, Logistics Services Division, OL

SUBJECT: Security Requirements for New Situation Room - 1E-4846

REFERENCE: Request for Approval of Situation Room Construction in Room 1E-4846, Headquarters Building, from [REDACTED] dated 22 April 1964

25X1A8a

1. Surveys of the subject area were conducted by the Survey Branch, Physical Security Division and coordinated with appropriate offices. Based upon the results of these surveys, the following security and safety recommendations are made in order to convert subject area into a situation room:

a. Security Requirements

- (1) Seal up door at 1E-4840 to match existing walls.
- (2) New L shaped interior wall to match existing L shaped wall (1E-4840 corridor wall and block 41, wall template plan). All walls to be slab-to-slab including existing walls.
- (3) Install Mosler One Hour vault door left swing constructed in accordance with FD 63441-3 and equipped with an S&G T-8400 series combination lock. This door to be contact alarmed.
- (4) The situation room to be equipped with a Kidde Ultrasonic Alarm.
- (5) Duct work or other such openings over 96 square inches entering the situation room should be firmly secured with 9-11 gauge expanded metal.

04-2941

~~SECRET~~
GROUP 1
Excluded from automatic
downgrading and
declassification