

# DISPATCH

CLASSIFICATION

~~CONFIDENTIAL~~

PROCESSING ACTION

MARKED FOR INDEXING

NO INDEXING REQUIRED

ONLY QUALIFIED DESK  
CAN JUDGE INDEXING

MICROFILM

25X1A

TO

CHIEF OF STATION, [REDACTED]

INFO.

FROM

DIRECTOR OF LOGISTICS

SUBJECT

25X1A

[REDACTED] - VOLTAGE REGULATORS

ACTION REQUIRED - REFERENCES

25X1A

REF [REDACTED] - 0762

1. PARAGRAPH 2 OF REFERENCE. REBUILD OF SINGLE PHASE UNIT AS TEMPORARY FIX APPROVED.

2. PARAGRAPH 3 OF REFERENCE QUESTION 500 KVA RATING. WILL AN INCREASE OF REGULATOR RATING OF 3.47 TIMES THE PRESENT REGULATOR RATING BE CONSISTENT WITH PLANS FOR DISTRIBUTION SYSTEM? HAS CONSIDERATION BEEN GIVEN TO THE DECREASE FLEXIBILITY OF THE THREE PHASE REGULATOR OVER THE THREE SINGLE PHASE REGULATORS? IS IT NECESSARY TO REGULATE THE THIRD LINE? REGULATOR NOT DESIGNED FOR POWER SURGES. POSSIBLY RECLOSERS OR LIGHTNING ARRESTORS NECESSARY TO PROTECT ELECTRICAL EQUIPMENT.

3. IF CONSIDERATION TO ABOVE HAS BEEN GIVEN, RECOMMEND REGULATOR WITH TAP CHANGING MECHANISM OVER CORE TYPE REGULATORS. FORWARD REQUISITION AS PER PARAGRAPH 5 OF REFERENCE.

[REDACTED]

25X1A

DISTRIBUTION  
VIA TELETAPE

2 - [REDACTED]

25X1A

CROSS REFERENCE TO		DISPATCH SYMBOL AND NUMBER	DATE
25X1A		[REDACTED]	1 AUGUST 1966
CLASSIFICATION		HQS FILE NUMBER	
25X1A		<del>CONFIDENTIAL</del> NOTHING FOLLOWS	NONE
25X1A		ORIGINATING	
25X1A		OFFICE	OFFICER
25X1A		OL/RECD/UEB/[REDACTED]	MLC
25X1A		EXT. 5696	
25X1A		COORDINATING	
25X1A		OFFICE SYMBOL	DATE
25X1A		FE/LOG	[REDACTED] /DBM/
25X1A		OFFICER'S NAME	
25X1A		RELEASING	
25X1A		OFFICE SYMBOL	DATE
25X1A		ACFE	[REDACTED]
25X1A		OFFICER'S SIGNATURE	
25X1A		[REDACTED]	

# DISPATCH